



SLICED OUTFALL INTO HAVERING DRAIN, APPROX 500M FROM SITE

RIVER THAMES

HAVERING DRAIN

OPTION 2
RIGHT OF EASEMENT, 1.5M EACH SIDE OF DRAIN

INTO THAMES VIA A BAFFLED OUTLET 420M AOD
OPTION 1


TO CONNECT TO PUBLIC SEWER @ 750 m DISTANT. MANHOLE APPROXIMATE LOCATION AT JUNCTION OF MARCH WAY AND FROG LANE. MAX DISCHARGE 7 L/S

FROG LANE

MARCH WAY

FOLVIEW

PLEASE NOTE ORIENTATION OF PLAN; TO SUIT DRAWING LAYOUT



RPS

Conrad House
Beaufort Square
Chepstow
Monmouthshire
NP16 5EP

Tel: 01291 621821
Fax: 01291 627827
email: rpssw@rpsgroup.com

Approved:

Revisions:

Date:
10.10.05

Drawn by:
K Ricketts

Scale:
N.T.S @ A3

Client:
Novera Energy

Job:
Sustainable Energy Facility
East London

Drawing Title:
Figure 12.2b
Drainage Plan for
Consultation (Sheet 2 of 2)

Drawing Number:
JER2943-Fig 12.2b